

Crushed

TOP VIEW

SIDE VIEW

Excavation - 20 cubic yards

4" Min

Separation

JOINT TRENCH DETAIL

Primary-Schedule 40 (NTS)

ROADSIDE

Final Grade

36'

Min

Cover

Phone & TV -

XFMR VAULT EXCAVATION DETAILS

Crushed

Rock

Excavated Dirt Pile -

Backfill for Schedule 40 Conduit

(NO Rocks over 10" Diameter

or foreign objects)

→ 24" Min → → To Excavated Dirt Pile

 Primary Power Cable in Customer Provided Schedule 40 Conduit

Rock

34KV (1 UNIT EACH, 3 WALLS)

VAULT GROUND INSERT

SIDE VIEW

Excavation - 19-1/2 cubic yards

SITE SPECIFIC NOTES

REMOVAL NOTES

V1 - V2

REMOVE (3) EXISTING 1/0 UG PRIMARY, L=640'

Approved 03/14/2016 kcoleman

INSTALLATION NOTES

AT INT1

SPLICE (4) 90 DEG BENDS INTO EXISTING UG PRIMARY 4" CONDUIT

INT1 - V3

INSTALL (4) RUNS OF 4" CONDUIT, L=80' EA.

AT V1 GRID# 226329-166944

INSTALL (3) LB ELBOWS PER STD. 6041.1000

AT V2 GRID# 226332-167007

INSTALL (3) LB ELBOWS PER STD. 6041.1000

AT V3 GRID# 226332-166986
* * * CUSTOMER TO EXCAVATE 11'X9'X6' WORKPIT * * *

INSTALL (1) 5' X 7' VAULT PER STD. 6050.1030 INSTALL (3) 4-POS. J-BOXES

INSTALL (9) LB ELBOWS PER STD 6041.1000

V1 - V3

INSTALL (3) RUNS OF 1/0 UG PRIMARY, L=530' INSTALL CABLE #'S EHA350, EHA351, AND EHA352

V2 - V3

INSTALL (3) RUNS OF 1/0 UG PRIMARY, L=270' INSTALL CABLE #'S EHA353, EHA354, AND EHA355

AT V4 GRID# 226314-166986

* * * CUSTOMER TO EXCAVATE 11'X11'X5' WORKPIT * * *

INSTALL 7' X 7' VAULT W/ 8' X 8' COVER INSTALL 500 kVA 120/208 XFMR PER STD. 6045.5000

INSTALL (3) LB ELBOWS PER STD. 6041.1000 INSTALL GRID# 226314-166986

CONNECT (6) RUNS OF CUSTOMER-OWNED 600 KCMIL UG SECONDARY

WO# 104277251

V3 - V4


INSTALL (2) RUNS OF 4" CONDUIT, L=250' EA.
INSTALL (3) RUNS OF 1/0 UG PRIMARY, L=280'
INSTALL CABLE #'S EHA356, EHA357, AND EHA358

POWER GENERAL NOTES - COMMERCIAL PROJECT


- All materials to be installed in accordance with Puget Sound Energy's (PSE) standards. Any deviation from this work sketch must be AUTHORIZED by PSE's Project Manager and NOTED on the Foremans' Copy.
- 2. All switching arrangements and/or outage arrangements are to be made with the Project Manager at least three (3) working days in advance.
- 3. Contact the Utilities Underground Location Center (1-800-424-5555) at least 48 hours prior to commencing work to get the underground facilities located.
- 4. STAKING: The customer will provide all staking (transformer, handhole, trench, grade, lot, pole, sidewalk,
- etc.). See sketch and details for locations. Equipment locations must be approved by the Project Manager.
- 5. SITE PREPARATION: The work area will be at or near finished grade, clear of trench spoils or construction materials which would restrict construction and/or equipment access, before work can begin.
- 6. Roads shall be paved or have a compacted, crushed rock base in place.
- 7. CLEARANCES: Transformers require a minimum of 6 feet from fire fighting equipment, 10 feet from combustible walls, overhangs, doors, and windows, and a minimum of 5 feet from the back of curb (or guard posts will be required per PSE standards). All conduits and vaults are to be at least 5 feet away from water, storm and sewer lines when paralleling them in the right of way, and at least 1 foot when crossing them.
- 8. All work is to be done in accordance with local municipal and county permit requirements as applicable.
- 9. Customer/Developer is responsible to provide, install and maintain all secondary service cables, conduits and crossings from the individual unit's meter base to the designated connection point.
- 10. Inclement weather conditions may cause delays in construction times and dates.

EROSION & SEDIMENT CONTROL REQUIREMENTS

EROSION & SEDIMENT CONTROL SHALL BE PER PSE STANDARD PRACTICE 0150.3200 TECHNIQUES FOR TEMPORARY EROSION & SEDIMENT CONTROL & ANY ADDITIONAL LOCAL JURISDICTION REQUIREMENTS. (LOCAL JURISDICTIONS MAY HAVE ADDITIONAL REQUIREMENTS INCLUDING NOTES DETAILING WHERE EROSION OR SEDIMENT CONTROL STRUCTURES ARE TO BE INSTALLED, CROSS SECTION DETAILS OF THE TYPICAL EROSION STRUCTURES, & SPECIAL REQUIREMENTS FOR WORK IN SENSITIVE AREAS.)







							. 0. 00	acto polott alai	1 000 07 122 1 02 (1	220 01 10)	
'Locates Requir		<u>veloper</u> Yes No	Х	Yes No	PS X	<u>E</u>	THIS SKE	TCH NOT TO BE RE		CALL (800) SS DAYS BEFORE LOCATION OF EXISTING	YOU DI
'Outages Required" Yes				No	Х		REAL E	STATE/EASE	MENT	PERMIT	
'Flagging Required" Yes			Χ	No				EASEM	KIRKLAND		
3							FUNCT	ION	CONTACT	PHONE NO	DATE
2							PROJE	CT MGR	M. BOSSHARDT	(425) 457-9295	2/8/16
1							ENGR -	- POWER	M. BOSSHARDT	(425) 457-9295	2/8/16
REV#	DATE	BY	DES	CRIPTIO	N		ENGR -	- GAS	N/A	N/A	N/A
COUNTY		Emer Sect	Gas	Wk Ctr	POWER	WK CTR	DRAW	N BY	A. SPRENGER	(425) 505-3988	2/8/16
KING		N/A		N/A		CSPFEPM	CHECK	ED BY			
1/4 SEC		OP MAP			PLAT M	AP	APPRO	VED BY			
N/A		N/	N/A			N/A	FOREM	FOREMAN #1			
U-MAP NO (POWER)		OH CKT MA	OH CKT MAP UG CKT N			CIRCUIT NO	FOREMAN #2				
2605E110		2605E13	32	2605	E110	JUA-11	MAPPII	NG			
					JOIN	T FACILITIES A	RRANGE	MENTS			
	UTILITIES		N/A			N/A			N/A	N/A	
(N/A			N/A			N/A	N/A		

NCIDENT N/A

N/A

N/A

MAOP N/A

Elect Order

105080255

PUGET SOUND US PRI. LINE EXT., INSTALL J-BOX, INSTALL PM XFMR 12215 NE 128TH ST., KIRKLAND, WA 98034

(12217 NE 128th St

SITE PLAN

TOP VIEW

GROUNDING PIGTAIL — FOR TELEPHONE &

TV #2 BARE COPPER

MAKE NEUTRAL CONNECTIONS — W/ COPPER "C" CLAMPS


INTERNAL VAULT GROUND -

THE GROUNDING BUS SHALL BE INSTALLED 6"

BELOW THE J-BOX W/ (2) CONNECTIONS TO THE J-BOX. STAND #2 Cu AWAY FROM VAULT WALL TO ALLOW SPACE FOR FUTURE INSTALLATION

SCALE: 1" = 50'

PRE-CONSTRUCTION UNDERGROUND CIRCUIT MAP



SCALE: NONE

CONDUIT DIAGRAM

POST-CONSTRUCITON UNDERGROUND CIRCUIT MAP

Loca	ition			Length (per		
From	То	Wire Size & Type	Quantity	conductor)	Remarks	
V01	V02	1/0 UG PRI.	3	640'		

Installed at site:

Grid Number:

kVA Rating:

Toreman to redline the following information

Company ID#:

Primary phase connected to:

Tested Secondary Voltage


J 2-4"


Vault & Equipment Table

Site Grid Number		Vault Size & Cover	31		Bushings	Transformer ID Numbers (Company ID)	ASBUILT INFORMATION Foreman-Complete
				LB	DC		
V01	226329 166944	-	-	3	-		
V02	226332 167007	-	-	3	-		
V03	226332 166986	5'X7'X5' Unistrut HH Matid: 7663200	-	9	-		
V04	226314 166986	7'X7'X4'-2" Unistrut HH Matid: 7917901	500KVA PM TRF 120/208 Matid: 6258250	3	-		

PRIMARY CABLE & CONDUIT TABLE

LOCAT	ION				C	ONDU	JIT					PRIMARY CABLE					ASBUILT INFORMATION		
		SIZE	Qty	LENGTH Design (ft)		BE	NDS		PULL	PULL	Cable	LENGTH Design (ft)	С	able Numbe	ers	Plea	ase Record		Foreman - Complete
FROM	то	(in)			90°	45°	22°	11°	(lbs)	Rev (lbs)	Size		Α	В	С	Manufacturer	Compound	Year	Actual Amount Installed (Conduit & Cable)
V1	V3	4"	1	80	2						1/0	530	EHA350	EHA351	EHA352				
V2	V3	4"	1	80	4						1/0	270	EHA353	EHA354	EHA355				
V3	V4	4"	1	250							1/0	280	EHA356	EHA357	EHA358				





	CABLE INFO.	
CABLE #	EHA350, EHA351, EHA352	
/EAR		
YPE		


CABLE INFO.

CABLE #	EHA353, EHA354, EHA355
YEAR	
TYPE	

CABLE INFO.

	o,	
CABLE #	EHA356, EHA357, EHA358	
/EAR		
YPE		

DEDICATED FACILITIES						
ORDER#	105080255	FOOTAGE				
2"	CONDUIT					
4"	CONDUIT	240'				
6"	CONDUIT					
1/0	CABLE	240'				
750	CABLE					



JUNCTION BOX DETAIL - V3

| PERMIT | KIRKLAND | | CONTACT | PHONE NO | DATE | | M. BOSSHARDT | (425) 457-9295 | 2/8/16 | M. BOSSHARDT | (425) 457-9295 | 2/8/16 | N/A | N/A | N/A | N/A | A. SPRENGER | (425) 505-3988 | 2/8/16 | |

REAL ESTATE/EASEMENT

FUNCTION PROJECT MGR

ENGR - GAS

DRAWN BY

EASEMENT



REV# DATE BY DESCRIPTION

Emer Sect | Gas Wk Ctr | POWER WK CTR

"Outages Required"

"Flagging Required"

KIRKLAND MEMORY CARE
UG PRI. LINE EXT., INSTALL J-BOX, INSTALL PM XFMR
12215 NE 128TH ST., KIRKLAND, WA 98034

10508025